
CHLORIDE TEST

Article Nr. T1440-01

TEST PROCEDURE

Salt content in boiler water, caused by leakage in the heat exchangers, is expressed by the content of chloride (Cl).



6. Multiply by 20 number of drops of titrant used.

Number of drops x 20 = ppm chloride. Low content of chloride, below 100 ppm, can be measured more accurately by filling the mixing bottle with water to the 23 ml mark. Number of drops x 5 = ppm chloride. Recommended max. content of chloride in boiler water is 200 ppm.

Drops x 20 = ...

